

Med Lock Series

*1x4 Recessed Flanged Luminaires for Advanced Surgical Suites
For Use in Straight Rows or Individual Layouts Only*

ML07

Specifications:

Housing: One piece, seam welded, hole free 18-gauge aluminum construction. Fully white powder coated.

Door Frame: 20-gauge CRS or type 304 stainless steel one piece inset door frame hinged to housing with two stainless steel cables. Secured by captive stainless steel screws.

Gaskets: NSF Listed extruded closed cell Nitrile gasketing located at interface of door and housing. NSF listed silicone seals the door to the lens.

Reflector: Die formed metal with high reflectance white polyester powder coat finish. (minimum reflectivity 88%)

Lens: Two piece acrylic lens system with an external clear lens for easy cleaning and a linear prismatic acrylic lens internal for light control. RFI shielded with a .375" metallic conductive grid that complies with radiated emissions (RE101) of Military Standard 461E. Consult factory for other lens options.

Lamps: See lamp options listed below. Lamps supplied by others.

Electrical: Standard ballasts - Electronic, less than 10% THD high performance instant start universal voltage (120-277 volt). See options for other choices. Each fixture is standard with one RFI line suppressor. Tested to surpass conducted emissions (CE102) of Mil. Std. 461e See Options for additional selections for ballasts and suppressor circuits.


Finish: White DuPont Alesta™ using Agion® silver ion antimicrobial powder coat finish standard for both doors and housings. See option SSP for satin polished stainless steel doors.

Installation: Adjustable toggle arm mounting standard. See Options for yoke mounting system (YOKE). Four .875" flattened and silicone sealed knockouts for wiring. Suitable for through wiring.


Listings: UL and CUL Listed for Wet Locations. Cleanroom ISO14644-1 Class 6 (Fed Std-209E class 1,000) IBEW Union Label. EMC tested and labeled for Mil-Std 461E. NSF-2 Listed, IP-65 dust and water resistance.

Project: _____
 Fixture Type: _____

Cross Section



Ceiling Cutout



Ordering Information:

ML - OF - - - - -

Series	Installation Type	Material	Size	Lamps	Voltage	Options
ML	OF = Flange	4= Alum. Hsg. & SS Door 5= Alum. Hsg. & CRS Door			120V 277V 347V UNV	FF = Fuse & Holder FD = Two Fuses & Holders FT = Three Fuses & Holders ESB = Magnetic Ballast (T8 32W only) EBPRS= Program Rapid Start Ballast DIM = Electronic Dimming Ballast** 1/EM = One Lamp Emergency Ballast (700 L) 2/EM = Two Lamp Emergency Ballast (1300 L) F/EM= Two Lamp Emergency Ballast (3000L)† 2/CIR= Two RFI Protected Switched Circuits 3/CIR= Three RFI Protected Switched Circuits GG = NSF listed SealPro™ Gasket SSP= Satin Polished SS Door P12/RFI= Prismatic P12 Acrylic w/RFI Grid PF= Plaster frame (For wet plaster ceilings) GL2= Two Green 550nm T8 lamps YOKE= Yoke Mounting System
1x4 = 1' x 4' Housing		1, 2 or 3/T8 = F32T8 32W T8 (G13) 1, 2 or 3/T5 = F28WT5 28W T5 (G5) 1, 2 or 3/T5HO = F54WT5 54W T5HO (G5)				

**Dimming ballasts are 0-10vdc type by manufacturer of our choice unless specified. Use DIM/(Model Name) to specify a certain dimming system.
 †Externally Mounted Emergency ballast is secured to top of fixture