

Installation and Maintenance *for:* EL, WL or KL-S Series

Installation

Important Safeguards

When Using Electrical Equipment, Basic Safety Precautions Must Always Be Followed, including the following:

Do Not Use This Product For Other Than Intended Use.

Caution: Service Must Be Performed By Qualified Service Personnel.

Do Not Install This Product Near Gas or Electric Heaters.

Use of Accessory Equipment Not Recommended by the Manufacturer May Cause an Unsafe Condition.

Read and Follow All Safety Instructions

Installation must be performed by qualified Service personnel.

1. With fixture body resting face up on a stable surface, open doorframe and remove internal reflector.
2. Locate mounting holes (4 each provided) and supply knockout locations (2 each provided) in the rear housing surface.
3. Select Supply Entry Method.
 - a. Direct conduit: Using the knockouts for supply connection. Remove silicone seal from knockout area. Create the Supply entrance hole in the plate by removing the revealed knockout using a screwdriver. Connect conduit fitting to plate. If a ground wire is required, attach it to the fixture using the stud and green nut provided.
 - b. Junction box: Remove plate and caulk area of housing around J-box to seal the fixture to the ceiling.
4. Locate mounting surface and/or structure capable of reliably supporting more than the weight of the fixture according to applicable building codes.
5. (Asymmetric only) Orient the fixture so that the internal arrow aims in the direction needed.
6. Secure fixture to mounting surface using minimum (4) 1/4-20 bolts with washers. This and all other hardware should be stainless steel if installed in a wet or damp location.
7. Rough in supply connections according to the NEC and local requirements using minimum 90C supply wiring materials.
8. (Optional) Seal with caulk the perimeter of the fixture where it contacts the mounting surface using site approved materials.
9. Remove any protective films from the outer surfaces as provided.
10. Replace reflector and secure reflector.
11. Install only the rated lamps. (See marking inside fixture for appropriate lamp type.)
12. Secure doorframe using Phillips screwdriver.
13. Energize fixture with the marked and rated voltage from a protected branch circuit. Please note: Fixture may be internally fused with a replaceable fuse element.